

Attachment F

Luminaire Schedule	Qty	Label	Arrangement	Description	LF	Air. Watts	Lum. Lumens
1	1	AA2H	Single	NLS NV-T-12-32L-7-30K-UNV-HSS MOUNT ON 12FT POLE WITH 2FT BASE	0.900	71	4247
1	1	AA3H	Single	NLS NV-T-13-32L-7-30K-UNV-HSS MOUNT ON 12FT POLE WITH 2FT BASE	0.900	71	7810
3	3	AA4	Single	NLS NV-T-14-32L-7-30K-UNV MOUNT ON 12FT POLE WITH 2FT BASE	0.900	71	7739
6	6	AA4H	Single	NLS NV-T-14-48L-1-40K-UNV-HSS MOUNT ON 12FT POLE WITH 2FT BASE	0.900	156	9672
1	1	AA5	Single	NLS NV-T-15-32L-7-40K MOUNT ON 18FT SQUARE POLE WITH 2FT BASE	0.900	71	8520

Calculation Summary	Units	Avg	Min	Max	Avg/Min	Max/Min
PROPERTY LINE Illuminance	Fc	0.09	0.4	0.0	N.A.	N.A.
SITE GROUND Illuminance	Fc	0.71	9.3	0.0	N.A.	N.A.



GENERAL NOTES:
 A. PULSE PRODUCTS DOES NOT ASSUME RESPONSIBILITY FOR THE INTERPRETATION OF THIS CALCULATION OR COMPLIANCE TO THE LOCAL, STATE, OR FEDERAL LIGHTING CODES OR ORDINANCES.
 B. LIGHTING LAYOUT IS NOT INTENDED FOR CONSTRUCTION DOCUMENTS BUT ONLY TO ILLUSTRATE THE PERFORMANCE OF THE PRODUCT.
 C. ALL READINGS/CALCULATIONS SHOWN ARE SHOWN ON OBJECTS/SURFACES.



#	Date	Comments

Revisions

Scale: AS NOTED

Date: 3/21/2023

Checked By: ROSS

Drawn By: SANDY

LINDEY'S STEAK HOUSE

ARDEN HILLS, MN